

Monitoring Data for the Goulburn Water Treatment Plant  
 233-235 Wheeo Road Goulburn  
 Licence 1649



Condition M6 - Volume Discharged

Location - Overflow pipe from Settling Dam on River Street

Date	Biochemical Oxygen Demand (mg/L)	Suspended Solids (mg/L)
11/01/2018	2	10
7/02/2018	2	8
7/03/2018	2	10
4/04/2018	2	9
2/05/2018	2	7
6/06/2018	2	2
4/07/2018	<2	5
16/08/2018	<2	7
5/09/2018	2	7
10/10/2018	<2	5
7/11/2018	<2	9
5/12/2018	<2	7

Limit	<b>20</b>	<b>50</b>
Average	<b>2.0</b>	<b>7.2</b>
Maximum	<b>2</b>	<b>10</b>
Minimum	<b>&lt;2</b>	<b>2</b>

Date Published : 21/06/2019

	January	February	March	April	May	June	July	August	September	October	November	December
1	200	200	150	100	50	200	200	0	75	200	50	0
2	50	0	200	175	150	0	100	50	75	175	150	50
3	125	75	50	0	200	75	100	150	200	150	200	100
4	200	175	75	75	0	150	175	200	150	200	0	150
5	0	50	125	150	75	200	150	50	200	50	150	200
6	75	100	175	200	150	50	75	125	150	175	50	0
7	100	175	50	50	200	125	200	175	175	200	125	125
8	175	50	100	100	50	200	175	0	75	175	200	200
9	50	125	175	200	100	0	175	75	100	150	0	0
10	100	200	75	50	200	75	125	150	150	100	75	50
11	175	0	125	125	0	125	200	200	175	75	150	125
12	200	75	200	200	75	150	50	0	200	100	200	200
13	0	175	0	0	150	50	100	100	75	175	0	0
14	125	50	75	75	200	200	150	200	75	200	100	75
15	200	100	150	150	50	200	150	50	200	175	150	125
16	50	200	200	200	100	125	200	125	175	150	200	200
17	100	50	50	0	175	200	50	175	150	75	0	0
18	175	125	175	100	50	175	150	50	175	75	75	50
19	50	200	200	150	150	150	175	100	175	175	150	100
20	125	50	0	200	200	150	100	150	150	200	50	175
21	150	100	100	0	0	200	125	200	75	175	125	0
22	200	175	150	75	75	0	200	0	200	150	200	50
23	0	50	200	150	150	100	175	75	150	100	0	125
24	100	100	50	200	200	175	175	125	100	175	100	200
25	200	150	125	50	50	175	100	200	100	75	175	0
26	50	200	175	125	75	200	50	50	200	175	200	50
27	125	0	0	175	100	150	75	150	150	200	0	75
28	200	100	75	50	200	150	200	200	150	175	75	150
29	50		150	100	0	100	175	175	75	200	100	200
30	75		200	150	75	50	150	50	200	150	175	0
31	150		50		125		200	150		175		50