

Monitoring Data for the Goulburn Wastewater Treatment System
 Licence 1742 Condition M2 - Required Monitoring
 Monthly Monitoring



Point 25

Date	Biochemical Oxygen Demand (mg/L)	Conductivity (mg/L)	Faecal Coliforms (cfu/100ml)	Nitrogen (total) (mg/L)	Oil and Grease (mg/L)	Phosphorus (total) (mg/L)	Sodium (mg/L)	Total Suspended Solids (mg/L)	pH	Ammonia (mg/L)	Chlorophyll 'a' (ug/L)	Total Aluminium (mg/L)
4/01/2017	4	867	53	7.64	<1	2.93	110	15	9.26	2.4	133	0.08
1/02/2017	6	865	<2	6.07	<1	1.4	127	46	9.9	0.1	338	0.08
1/03/2017	18	935	4060	14	<1	3.26	125	96	9.21	3.7	377	0.11
5/04/2017	6	925	<2	10	<1	4.98	128	19	8.69	5.8	164	0.07
3/05/2017	6	1030	2	18.7	<1	7.96	114	56	8.05	12.1	215	0.11
7/06/2017	7	1180	62	28.4	0	7.53	124	16	8.1	24.6	79.5	0.15
5/07/2017	4	1220	13	28.3	0	6.95	125	7	8.01	24.6	18.2	0.08
9/08/2017	0	1260	0	29.5	0	6.19	129	3	8.13	26.4	1.6	0.07
15/09/2017	6	1280	28	29.8	0	4.9	131	12	8.22	24.1	121	0.18
4/10/2017	8	1250	0	26.8	0	4.95	128	8	8.38	21.9	65.6	0.18
8/11/2017	9	1200	10	23.4	0	6.42	127	14	8.5	18.1	74.4	0.13
6/12/2017	6	1160	29	20.3	0	6.97	128	11	8.23	16.7	180	0.08
10/01/2018	6	1100	4	14.5	<1	6.95	126	6	8.79	10.7	64.2	0.08
7/02/2018	5	1120	14	10.9	<1	4.51	130	11	9.01	7.1	64.6	0.03
7/03/2018	7	1020	1440	8.65	<1	5.35	124	10	8.38	6.2	73.8	0.07
4/04/2018	7	1020	13800	16	<1	6.88	122	10	8.17	12.7	87.6	0.09
3/05/2018	4	1080	4	13.6	<1	7.25	125	6	8.45	12.8	85.9	0.05
6/06/2018	7	1080	3980	7.53	<1	5.74	106	14	8.21	18.1	147	0.07
4/07/2018	4	1150	104	23.7	<1	4.73	106	9	8.06	20.4	96.4	0.09
3/08/2018	4	1160	<2	24.2	<1	4.18	96.7	4	7.78	22.1	6.48	0.08
5/09/2018	5	1140	<2	27.6	<1	5.15	110	7	8.07	23.9	11.9	0.14
3/10/2018	8	1220	142	30.5	<1	6.91	106	15	8.09	29.8	49.4	0.14
7/11/2018	4	1120	62	28.6	<1	7.84	119	14	8.2	20.6	179	0.1
5/12/2018	16	1200	16	20.5	<1	8.11	126	10	7.87	16.3	43.7	0.04
9/01/2019	6	1140	<2	12.1	<1	6.92	127	11	8.39	6	73.8	0.07
6/02/2019	5	1080	<2	7.06	<1	5.7	131	26	8.52	2.6	186	0.05
6/03/2019	5	1090	<2	6.95	<1	8.5	134	5	8.05	5.2	4.2	0.03
4/04/2019	<2	1040	<2	5.4	<1	4.87	130	8	8.13	3.2	22.1	0.06
Limits	20				10			30				