

Monitoring Data for the Goulburn Wastewater Treatment System  
 License 1742                      Condition M2 – Required Monitoring  
 6 Monthly Monitoring



Point 40

Date	pH	Electrical Conductivity @ 25°C	Suspended Solids (SS)	Total Nitrogen as N	Total Phosphorus as P	Biochemical Oxygen Demand	Thermotolerant Faecal Coliforms (Confirmed)
3/04/2019	7.94	424	6	0.91	0.05	2	74
11/10/2019	8.2	623	7	0.95	0.04	3	12
8/04/2020	7.82	469	15	0.67	0.04	<2	108
7/10/2020	8.03	434	7	0.82	0.04	<2	22
7/04/2021	7.83	469	11	1.62	0.08	2	150
6/10/2021	7.92	534	7	1.03	0.04	<2	56
18/4/2022	7.88	347	8	1.58	0.07	<2	640
26/10/2022	7.94	300	18	1.47	0.09	2	126