

Monitoring Data for the Goulburn Wastewater Treatment System  
 License 1742                      Condition M2 – Required Monitoring  
 6 Monthly Monitoring



Point 40

Date	pH	Electrical Conductivity @ 25°C	Suspended Solids (SS)	Total Nitrogen as N	Total Phosphorus as P	Biochemical Oxygen Demand	Thermotolerant Faecal Coliforms (Confirmed)
3/04/2019	7.94	424	6	0.91	0.05	2	74
11/10/2019	8.2	623	7	0.95	0.04	3	12
8/04/2020	7.82	469	15	0.67	0.04	<2	108
7/10/2020	8.03	434	7	0.82	0.04	<2	22
7/04/2021	7.83	469	11	1.62	0.08	2	150