

Monitoring Data for the Goulburn Wastewater Treatment System  
 License 1742 Condition M2 – Required Monitoring  
 Monthly Monitoring



Post UV

Date	pH	Electrical Conductivity @ 25°C	Suspended Solids (SS)	Total Nitrogen as N	Total Phosphorus as P	Oil and Grease	Biochemical Oxygen Demand	Thermotolerant Faecal Coliforms (Confirmed)
9/01/2019	8.11	965	<2	2.18	0.43	<1	<2	<2
6/02/2019	8	919	<2	3.2	5.57	<2	<1	<1
6/03/2019	8.01	976	<2	3.83		<1	<2	<1
4/04/2019	7.93	854	<2	5.8	0.87	<1	<2	<1
1/05/2019	7.83	956	<2	4.61	0.08	<1	<2	1
5/06/2019	7.54	720	<2	5.22	0.02	<1	<2	<1
3/07/2019	7.64	866	<2	10.6	0.05	<1	<2	<2
7/10/2019	7.62	967	<2	8.11	0.26	<1	<2	<2
7/08/2019	7.62	967	2	11.2	0.26	<1	<2	<1
2/10/2019	7.74	965	2	3.55		<1	<2	<2
11/10/2019	7.8	1040	<2	4.45	0.03	<1	<2	<2
12/11/2019	7.34	1020	4			<1	<2	<2
10/12/2019	8	954	6			<1	2	<2
8/01/2020	7.82	946	<2	5.3	0.36	<1	<2	<1
6/02/2020	7.88	1030	3	5.75	0.16	<1	<2	<1
4/03/2020	8.08	876	<2	6.93	0.16	<1	<2	<2
8/04/2020	7.89	891	<2	5.76	0.06	<1	<2	<1
6/05/2020	7.76	950	3	10.3	0.06	<1	<2	<1
9/06/2020	7.94	1110	<2	3.68	0.11	<1	<2	<1
7/07/2020	7.91	1160	<2	6.99	0.22	<1	<2	<1

Date	pH	Electrical Conductivity @ 25°C	Suspended Solids (SS)	Total Nitrogen as N	Total Phosphorus as P	Oil and Grease	Biochemical Oxygen Demand	Thermotolerant Faecal Coliforms (Confirmed)
5/08/2020	7.87	1020	<2	6.01	0.08	<1	<2	<2
2/09/2020	7.58	866	2	6.55	0.05	<1	<2	<2
7/10/2020	8.18	931	<2	3.89	0.06	<1	<2	<2
5/11/2020	7.82	858	4	8.12	0.01	<1	<2	<2
2/12/2020	7.54	947	3	5.05	0.06	<1	<2	<2
6/01/2021	7.67	924	4	2.43	0.04	<1	<2	<1
3/02/2021	7.38	724	2	7.85	0.02	<1	<2	<1
30/03/2021	7.83	1060	3	3.98	0.07	<1	<2	<1
7/04/2021	7.89	911	<2	5.64	0.05	<1	<2	<1
5/05/2021	7.91	905	<2	5.01	0.05	<1	<2	<1
2/06/2021	7.73	986	4	5.79	0.06	<1	<2	<1
7/07/2021	7.61	935	<2	7.63	0.02	2	<2	<2
4/08/2021	7.64	806	<2	6.28	0.02	<1	<2	<1
1/09/2021	7.74	870	2	9.68	0.02	<1	<2	4
6/10/2021	7.85	950	3	4.56	0.06	<1	<2	<2
3/11/2021	7.44	944	<2	1.96	0.05	<1	<2	2
2/12/2021	7.9	838	<2	7.4	0.02	<1	<2	<2
12/01/2022	8.02	918	4	7.07	0.06	<1	<2	<1
9/02/2022	7.82	945	9	8.62	0.13	<1	<2	<2
18/03/2022	8	796	5	15.3	0.08	<1	<2	<1
13/04/2022	7.95	854	3	6.95	0.06	<1	<2	<2
10/05/2022	8.13	944	<2	2.6	0.09	<1	<2	<1
7/06/2022	7.66	858	<2	3.48	0.04	<1	<2	<1
13/07/2022	8.22	821	6	2.04	0.04	<1	<2	<1
4/08/2022	7.65	964	<2	5.04	0.04	<1	<2	<2
7/09/2022	7.84	1040	<2	6.70	0.08	<1	<1	<1

Date	pH	Electrical Conductivity @ 25°C	Suspended Solids (SS)	Total Nitrogen as N	Total Phosphorus as P	Oil and Grease	Biochemical Oxygen Demand	Thermotolerant Faecal Coliforms (Confirmed)
21/10/2022	8.01	781	<2	12.4	0.04	<1	<1	<1
24/11/2022	7.8	759	<2	10.2	0.1	<1	<2	<1
20/12/2022	7.85	976	9	5.08	0.24	<1	2	<1
18/1/2023	7.68	1030	<2	2.57	0.39	<1	<2	<1