

Monitoring Data for the Goulburn Wastewater Treatment System
 License 1742 Condition M2 – Required Monitoring
 6 Monthly Monitoring



Point 41

Date	pH	Electrical Conductivity @ 25°C	Suspended Solids (SS)	Total Nitrogen as N	Total Phosphorus as P	Biochemical Oxygen Demand	Thermotolerant Faecal Coliforms (Confirmed)
3/04/2019	7.90	398	8.00	0.77	0.04	2.00	50.00
11/10/2019	8.71	601	5.00	1.24	0.03	3.00	6.00
8/04/2020	7.77	484	10.00	2.00	0.08	3.00	56.00
7/10/2020	8.03	444	8.00	1.03	0.04	<2	19.00
7/04/2021	7.77	452	7.00	1.36	0.06	<2	155.00
6/10/2021	7.78	579	5.00	1.16	0.04	<2	72.00
18/4/2022	7.86	329	15.00	0.41	1.42	<2	120.00
26/10/2022	7.91	329	15.00	1.15	0.03	2.00	12.00
19/4/2023	8.09	698	8.00	1.15	0.03	2.00	12.00
5/10/2023	8.09	702	21.00	0.24	0.06	2.00	80.00

